

4 February 2019



Planning Policy Project Manager

Sent by email to: [planningpolicy@chichester.gov.uk](mailto:planningpolicy@chichester.gov.uk)

David Wilson  
E: [drwilson@savills.com](mailto:drwilson@savills.com)  
DL: +44 (0) 1189520505

Ground Floor, Hawker House  
5-6 Napier Court  
Napier Road  
Reading RG1 8BW

[savills.com](http://savills.com)

Dear Sir/Madam

## **CHICHESTER LOCAL PLAN REVIEW - COMMENTS ON BEHALF OF THAMES WATER**

Thames Water Utilities Ltd (Thames Water) Property Services function is being delivered by Savills (UK) Limited as Thames Water's appointed supplier. Savills are therefore pleased to respond to the above consultation on behalf of Thames Water in relation to their statutory undertakings.

Thames Water are the statutory sewerage undertaker for a small part of the northern area of the District around Haslemere and are hence a "**specific consultation body**" in accordance with the Town & Country Planning (Local Planning) Regulations 2012.

We have the following comments on behalf of Thames Water:

### **Policy S12: Infrastructure Provision - Comments In Relation to Sewerage/Wastewater Infrastructure**

Thames Water support the policy in principle where it refers to water supply and foul sewer infrastructure, but consider that it can be improved with more detailed reference to wastewater/sewerage infrastructure requirements.

Thames Water seeks to co-operate and maintain a good working relationship with local planning authorities in its area and to provide the support they need with regards to the provision of sewerage/wastewater treatment [and water supply] infrastructure.

Water and wastewater infrastructure is essential to any development. Failure to ensure that any required upgrades to the infrastructure network are delivered alongside development could result in adverse impacts in the form of internal and external sewer flooding and pollution of land and water courses and/or low water pressure.

A key sustainability objective for the preparation of Local Plans and Neighbourhood Plans should be for new development to be co-ordinated with the infrastructure it demands and to take into account the capacity of existing infrastructure. Paragraph 20 of the revised National Planning Policy Framework (NPPF), July 2018, states: "*Strategic policies should set out an overall strategy for the pattern, scale and quality of development, and make sufficient provision for... infrastructure for waste management, water supply, wastewater...*"

Paragraph 28 relates to non-strategic policies and states: "*Non-strategic policies should be used by local planning authorities and communities to set out more detailed policies for specific areas, neighbourhoods or types of development. This can include allocating sites, the provision of infrastructure...*"

Offices and associates throughout the Americas, Europe, Asia Pacific, Africa and the Middle East.

Savills (UK) Limited. Chartered Surveyors. Regulated by RICS. A subsidiary of Savills plc. Registered in England No. 2605138.  
Registered office: 33 Margaret Street, London, W1G 0JD



Paragraph 26 of the revised NPPF goes on to state: “*Effective and on-going joint working between strategic policy-making authorities and relevant bodies is integral to the production of a positively prepared and justified strategy. In particular, joint working should help to determine where additional infrastructure is necessary....*”

The web based National Planning Practice Guidance (NPPG) includes a section on ‘water supply, wastewater and water quality’ and sets out that Local Plans should be the focus for ensuring that investment plans of water and sewerage/wastewater companies align with development needs. The introduction to this section also sets out that “Adequate water and wastewater infrastructure is needed to support sustainable development” (Paragraph: 001, Reference ID: 34-001-20140306).

It is important to consider the net increase in water and wastewater demand to serve the development and also any impact that developments may have off site, further down the network. The new Local Plan should therefore seek to ensure that there is adequate water and wastewater infrastructure to serve all new developments. Thames Water will work with developers and local authorities to ensure that any necessary infrastructure reinforcement is delivered ahead of the occupation of development. Where there are infrastructure constraints, it is important not to under estimate the time required to deliver necessary infrastructure. For example: local network upgrades take around 18 months and Sewage Treatment & Water Treatment Works upgrades can take 3-5 years.

The provision of water treatment (both wastewater treatment and water supply) is met by Thames Water’s asset plans and from the 1st April 2018 network improvements will be from infrastructure charges per new dwelling.

From 1st April 2018, the way Thames Water and all other water and wastewater companies charge for new connections has changed. The changes mean that more of Thames Water’s charges will be fixed and published, rather than provided on application, enabling you to estimate your costs without needing to contact us. The services affected include new water connections, lateral drain connections, water mains and sewers (requisitions), traffic management costs, income offsetting and infrastructure charges.

Information on how off site network reinforcement is funded can be found here <https://developers.thameswater.co.uk/New-connection-charging>

Thames Water therefore recommends that developers engage with them at the earliest opportunity (in line with paragraph 26 of the revised NPPF) to establish the following:

- The developments demand for water supply and network infrastructure both on and off site;
- The developments demand for Sewage/Wastewater Treatment and network infrastructure both on and off site and can it be met; and
- The surface water drainage requirements and flood risk of the development both on and off site and can it be met.

Thames Water offer a free Pre-Planning service which confirms if capacity exists to serve the development or if upgrades are required for potable water, waste water and surface water requirements. Details on Thames Water’s free pre planning service are available at: <https://www.thameswater.co.uk/preplanning>

In light of the above comments and Government guidance we consider that the New Local Plan should include a specific reference to the key issue of the provision of water and sewerage/wastewater infrastructure to service development proposed in a policy. This is necessary because it will not be possible to identify all of the water/sewerage infrastructure required over the plan period due to the way water companies are regulated and plan in 5 year periods (Asset Management Plans or AMPs). We recommend the Local Plan include the following policy/supporting text:

## **PROPOSED NEW WATER/WASTEWATER INFRASTRUCTURE TEXT**

***“Where appropriate, planning permission for developments which result in the need for off-site upgrades, will be subject to conditions to ensure the occupation is aligned with the delivery of necessary infrastructure upgrades.”***

***“The Local Planning Authority will seek to ensure that there is adequate water and wastewater infrastructure to serve all new developments. Developers are encouraged to contact the water/waste water company as early as possible to discuss their development proposals and intended delivery programme to assist with identifying any potential water and wastewater network reinforcement requirements. Where there is a capacity constraint the Local Planning Authority will, where appropriate, apply phasing conditions to any approval to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of the relevant phase of development.”***

Local Authorities should also consider both the requirements of the utilities for land to enable them to meet the demands that will be placed upon them. This is necessary because it will not be possible to identify all the water and wastewater/sewerage infrastructure required over the plan period due to the way water companies are regulated and plan in 5 year periods (AMPs). We are currently in the AMP6 period which runs from 1st April 2015 to 31st March 2020 and does not therefore cover the whole Local Plan period. AMP7 will cover the period from 1st April 2020 to 31st March 2025. The next Price Review, whereby the water companies' AMP7 Business Plan will be agreed with Ofwat, takes place in 2019.

We therefore request that the new Local Plan include the following policy/supporting text:

***“The development or expansion of water supply or waste water facilities will normally be permitted, either where needed to serve existing or proposed development in accordance with the provisions of the Development Plan, or in the interests of long term water supply and waste water management, provided that the need for such facilities outweighs any adverse land use or environmental impact that any such adverse impact is minimised.”***

I trust the above is satisfactory, but please do not hesitate to contact me if you have any queries.

Yours faithfully



David Wilson BA (Hons), BTP, MRTPI  
Associate Director Planning